

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001


NO.F6/DFS/MS/School/2019/SZ/ 866

Dated: 22/4/19

FIRE SAFETY CERTIFICATE


Certified that the Maxfort School Dwarka, located at Sector-7, Dwarka, New Delhi-110075, comprised of basement ground plus three upper floors owned/occupied by Samarjit Educational Welfare & Charitable Education Society (Regd.) was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2015/SZ/1868 dated 19.10.2015. Now the management has constructed one more upper floor, and now building is comprised of basement, ground plus Four upper floors & have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire Service Rules 2010, and verified by the officers concerned of fire service on 10.4.2019 in presence of Dr.V.K Gautam (Education Advisor) & Sh. S B Tripathi (Admin.) and that the premises/building is fit for occupancy class B "Educational building" with effect from 22.4.19 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 printed overleaf.


Issued on22.4.19..... at New Delhi by


(Atul Garg)
Chief Fire Officer

Copy to:-

1. The Dy. Director, (Education), G.N.C.T of Delhi, Old Secretariat, New Delhi-110054.
- ✓ 2. The Education Advisor, Maxfort School Sector-7, Dwarka, New Delhi-110075.
3. The Dy. Director (L&I), Builg., DDA, Vikas Sadan, INA, New Delhi.


Ms. Priyanka Bhatkoti
Principal
Maxfort School
Dwarka
New Delhi-110075


Education Advisor
MAXFORT SCHOOL
Sector-7, Dwarka
New Delhi-110075

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. 6 Mts. Wide Access roads for movement of fire units in case of emergency all around the building shall be kept free from any hindrance.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
1. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
2. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
3. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized occupancy or use of land if any.
4. All comments / directions of licensing Department shall always be permitted and followed.
5. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub-Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.