



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/162

Dated: 17/02/2025

FIRE SAFETY CERTIFICATE

Certified that the building of **Maxfort School** located at Plot No. 9, Sector-7, Dwarka, New Delhi-110075, comprised of Basement, Ground & 4 Upper Floors, was issued FSC by this department vide letter No. F6/DFS/MS/School/SZ/2022/385 dated 06/04/2022. The premise was re-inspected by the officer concerned of this department on dated 31/01/2025 in the presence of Sh. Jaiveer Singh (System Admn) and found that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the said premises is fit for occupancy class "**Educational Building**" with effect from 17/02/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/02/2025 at New Delhi by

(Atul Garg)
Director
Delhi Fire Service
04/02

Copy to: -

1. The Manager, Maxfort School located at Plot No. 9, Sector-7, Dwarka, New Delhi-110075
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Condition for the validity of fire safety certificate:

- 1 The stairs/ passage shall be kept clear from any obstruction & free from lock & key, as seen during the inspection otherwise the FSC shall be null & void
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 Basement shall be used strictly in accordance with BBL.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
- 7 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of DFS Rules, 2010, form is available on www.dfs.delhigovt.nic.in.