



ACE TEST HOUSE

(GOVT. APPROVED TESTING LABORATORY)

ISO 9001-2015 OHSAS 45001:2018 ISO 14001:2015
Certified Testing Laboratory



Committed to Precision....

Head Office. Kh. No. 1048/1088, Pepsi Wall Gali, Near Laxmi Narayan Mandir, Village-Bhalaswa, Delhi-110033
M: +91-7042858881/82/83 E-mail : acetesthouse@gmail.com, website : www.acetesthouse.com

TEST REPORT

(THIS CERTIFICATE IS NOT VALID WITHOUT A HOLOGRAM)

Page 1 of 1
A0003

Job Card No./ Job I.D. No.	30-20251103-05	Discipline	Chemical Testing
Report No.	ATH30-20251110-003	Group	Water
Sample Type	Drinking Water	Make	--
Name and Address of Customer	Maxfort School Dwarka New Delhi, Plot No.9, Sector-7, Main Road Dwarka, New Delhi-110075	Grade	--
Reference No.	--	Dated	03-11-2025
Agreement No.	--	Date of Receipt	03-11-2025
Name of Work	--	Start Date of Analysis	04-11-2025
Name of Agency/Contractor	--	End Date of Analysis	10-11-2025
Indian Standard Reference	IS:10500-2012	Report Issue Date	10-11-2025
Any other Information	Sample Collected From:-School	Location	--

Sr. No.	Test Parameter	Unit Of Measurements	Results	Requirement As per IS:10500-2012	Method Reference
Physical Properties					
1)	Colour	Hazen	<5	5.0 Max	IS:3025(Pt-4)-2021
2)	Odour	--	Agreeable	Agreeable	IS:3025(Pt-5)-2018
3)	Taste	--	Agreeable	Agreeable	IS:3025(Pt-7)-2017
4)	Turbidity	NTU	<1.0	1.0 Max.	IS:3025(Pt-10)-2023
5)	pH Value (at 25±2°C)	--	7.28	6.5 to 8.5	IS:3025(Pt-11)-2022
6)	Total Dissolve Solids	mg/l	350	500 Max	IS:3025(Pt-16)-2023
Chemical Properties					
1)	Iron (as Fe)	mg/l	Below detection limit	0.3 Max.	IS:3025(Pt-53)-2003
2)	Chloride (as Cl)	mg/l	58.46	250 Max.	IS:3025(Pt-32)-1988
3)	Fluoride (as F)	mg/l	0.12	1 Max.	IS:3025(Pt-60/Sec-1)-2023
4)	Free Residual Chlorine	mg/l	Below detection limit	0.2 Min.	IS:3025(Pt-26)-2021
5)	Total Hardness (as CaCO3)	mg/l	72	200 Max.	IS:3025(Pt-21)-2009
Micro-Biological Parameters					
1)	Total Coliform Organism	---	Absent	Shall not be detectable in 100ml sample	IS: 1622-1981
2)	Escherichia Coli	---	Absent	Shall not be detectable in 100ml sample	IS: 1622-1981

Remark : The sample conforms to IS: 10500-2012 w.r.to the above tests.

End Of Report

for Director's Signature

Delhi

Education Adv
Maxfort School
New Delhi

Dehradun



Scan to Verify

Jaipur

Principal
Maxfort School Dwarka
New Delhi

Principal
Maxfort School Dwarka
New Delhi


Authorised Signatory

TECHNICAL
MANAGER
Jammu

Terms & Conditions : ① Test reports are valid only for the sample tested in our laboratory. ② Sample will be stored/kept in our stores for 30 days from the date of testing and shall be destroyed thereafter without any intimation. ③ Samples tested are non-refundable in any case ④ This report will not be valid for judicial purpose. ⑤ Total liability of our test house is limited to invoiced amount.



MUNICIPAL CORPORATION OF DELHI
OFFICE OF DEPUTY HEALTH OFFICER
NAJAFGARH ZONE



No: DHO/NGZ/MCD/2025/D- 360

Dated- 29/05/2025

SCHOOL HEALTH CERTIFICATE

1. Name of the School: - MAXFORT SCHOOL DWARKA
2. SCHOOL ADDRESS – PLOT NO. 9, SEC-7, MAIN DWARKA ROAD, NEW DELHI-110075.
3. NO. OF SHIFT ONE TIMING Morning. 07:30 AM TO 02:30 PM
4. NO. OF STUDENTS: BOYS- 1909 GIRLS – 1420 TOTAL = 3329
5. NO. OF STAFFS: MALE -30 FEMALE – 149 TOTAL = 179

Details of Accommodations present in School


1. Floor Space in the Classroom Sufficient/insufficient **SUFFICIENT**
2. The Classrooms are Well Lighted/ill lighted **WELL LIGHTED**
3. The Classrooms are Well Ventilated/ill ventilated **WELL VENTILATED**
4. The Classrooms are kept / Not kept Neat & Clean: **NEAT AND CLEAN**
5. The Building requires/does not required Whitewash etc. **NOT REQUIRED**
6. The Drinking Water is Wholesome/Not wholesome **WHOLESOME**
7. The Latrine arrangement is Sanitary/Insanitary **SANITARY FROM HEALTH POINT OF VIEW.**

No. of toilets seats for student


1. One latrine-cum-urinal is required for 25 female student, so total is **SUFFICIENT**
 2. One latrine for 40 male student is required so total is **SUFFICIENT**
 3. Separate Toilet arrangement for staff present: Yes/No **YES SEPARATE EXISTS FOR STAFF.**
 4. The Overall facilities: Good/ Adequate/Inadequate **GOOD FROM HEALTH POINT OF VIEW.**
- If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard*

Education Advisor
Maxfort School Dwarka
New Delhi

Yes


Deputy Health Officer
Najafgarh Zone
Municipal Corporation Of Delhi
Health Deptt., Najafgarh Zone

(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)


Principal
Maxfort School Dwarka
New Delhi